

must meet the requirements of paragraph (d) of this section. The actual length of the space may not exceed 40 meters (131 feet).

(d) If the equivalent main vertical zone length under paragraph (c) of this section exceeds 40 meters (131 feet), both decks connected by the balcony must be protected with an automatic sprinkler system meeting NFPA 13.

(e) If the unobstructed balcony opening area is less than 93 square meters (1,000 square feet), the opening must be protected in accordance with NFPA 13 or other standard specified by the Commandant. The horizontal projection area of stairs, escalators, statues, or other obstructions must be subtracted from the total balcony opening area for purposes of computation of unobstructed balcony opening area.

[CGD 85-080, 61 FR 900, Jan. 10, 1996, as amended at 62 FR 51350, Sept. 30, 1997; 62 FR 64305, Dec. 5, 1997]

§ 116.440 Atriums.

(a) The atrium opening area must be a minimum of 93 square meters (1000 square feet) or 20% of the gross deck area of the largest deck within the accommodation space containing the atrium, whichever is smaller.

(1) Each side of an atrium opening must be a minimum of 6.1 meters (20 feet) in length. If the opening is circular or ellipsoid, it must measure at least 6.1 meters (20 feet) across in any direction.

(2) Any deck opening within an atrium must fit wholly within the horizontal projection of any deck opening of an upper deck.

(3) The horizontal projection area of stairs, escalators, statues, etc. within the atrium shall not be included for purposes of computation of atrium opening area.

(b) The entire main vertical zone containing an atrium must be protected throughout with a smoke detection system of an approved type which is installed in accordance with § 76.33 in subchapter H of this chapter. However, on vessels with no overnight passenger accommodations, smoke detectors may be omitted from the accommodation space containing the atrium.

(c) The entire main vertical zone containing an atrium must be protected

with an automatic sprinkler system meeting NFPA 13.

(d) The atrium must be provided with a smoke extraction system that complies with either:

(1) The smoke extraction system must be capable of exhausting the entire volume of the space within 10 minutes. The smoke extraction system must be capable of being activated by both the smoke detection system and by manual control, and designed with sufficient plenum air openings to prevent excessive negative air pressure in the atrium; or,

(2) The smoke extraction system may be designed in accordance with the principles of NFPA 92B "Smoke Management Systems in Malls, Atria, and Large Areas."

(e) Each level within the atrium must have two independent means of escape that comply with § 116.500 of this part. At least one of the means of escape must be a stairtower.

[CGD 85-080, 61 FR 900, Jan. 10, 1996, as amended at 62 FR 51350, Sept. 30, 1997]

Subpart E—Escape and Embarkation Station Requirements

§ 116.500 Means of escape.

(a) Except as otherwise provided in this section, each space accessible to passengers or used by the crew on a regular basis, must have at least two means of escape, one of which must not be a watertight door.

(b) The two required means of escape must be widely separated and, if possible, at opposite ends or sides of the space to minimize the possibility of one incident blocking both escapes.

(c) Subject to the restrictions of this section, means of escape may include normal exits and emergency exits, passageways, stairways, ladders, deck scuttles, and windows.

(d) The number and dimensions of the means of escape from each space must be sufficient for rapid evacuation in an emergency for the number of persons served as determined using § 116.438(n)(2) of this part.

(e) The dimensions of a means of escape must be such as to allow easy movement of persons when wearing life jackets. There must be no protrusions